

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1328:101 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Air Balance, 7301 International Drive, Holland OH 43528
Contact: Chuck Schneider (419) 865-5000 *FAX (419) 865-1375

DESIGN: Model 319-P fire damper. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as a 3-hour fire-rated damper.

- NOTE:
1. Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for listed leakage dampers.
 2. Formerly 3225-0206:016

*Rev. 06-08-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**